




PANEL N. XX

PATCH PANEL

PANEL N. XX

PANEL N. XX

PANEL N. XX



- CENTRAL ACQUISITION SYSTEM
 BASED ON IEC 62056-21
- CEWE CEWECONFIG
 - CEWE CETRICS
 - MV90
 - KISTERS SODA
 - GEORLITZ ENVZ000 (ENERGY LINK)
 - ENERGIYCT EISERWER
 -

Is possible to connect more meter using another COM port on PC

Fibre optic transducer
 Mod. STAER ST-M-62

Fibre optic cable (2 fibre)

MAX 32 on same bus.